



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	2520-1701:0103		
CATEGORY:	2520 - TREATED LUMBER		
LISTEE:	HOOVER TREATED WOOD PRODUCTS, INC. 154 WIRE ROAD, THOMSON, GA, 30824 Contact: Athari,Chris (706) 755-5350 (706) 595-6600 Email: cathari@frtw.com		
DESIGN:	<p>Treated Lumber with PYRO-GUARD. Products are pressure impregnated with "PYRO-GUARD" fire retardant chemical. PYRO-GUARD covers the following species of lumber:</p> <p>Douglas Fir, Alpine Fir, Southern Yellow Pine, Lodgepole Pine, White Spruce, White Fir, Hem/Fir, and SPF.</p> <p>Refer to listee's printed installation instructions for additional detailed product description and construction.</p>		
RATING:	Species	Flame Spread	Smoke Developed
	Douglas Fir	10	20
	Alpine Fir	10	0
	Southern Yellow Pine	10	20-50
	Lodgepole Pine	10	0
	White Spruce	10	0
	White Fir	5	0
	Hem/Fir	5	0
	SPF	10	0
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.		
MARKING:	Listee's name, product identification, classification, and UL label.		



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:

Listed as fire retardant treated lumber for interior use only. Listed as Class A products in accordance with ASTM E-84. In test of 30 minute duration, flame spread did not progress more than 10.5 feet beyond the centerline of the burners and no significant progressive combustion was present. The lumber must be pressure treated at the factory under authorized service inspection.

NOTES:

Corrected 11-03-11 jdd



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/24/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division