

# SUBMITTAL SHEET Tech Support: 305.634.0012

PRODUCT CATEGORY: ProSTUD

PRODUCT NUMBER: 600PDS125-33

COATING: G40 (G60/G90 Available)

#### PHYSICAL PROPERTIES

 WEB DEPTH:
 6.000 IN

 FLANGE HEIGHT:
 1.250 IN

 DESIGN THICKNESS:
 0.0346 IN

 YIELD:
 33 KSI

 WEIGHT:
 1.03 LB/LFT



**EFFECTIVE SECTION PROPERTIES** 

### **GROSS SECTION PROPERTIES**

CROSS SECTIONAL AREA (A):	0.303 IN <sup>2</sup>	EFFECTIVE AREA (Ae):	0.13 IN <sup>2</sup>
MOMENT OF INERTIA (IX):	1.463 IN <sup>4</sup>	MOMENT OF INERTIA (Ix):	1.428 IN <sup>4</sup>
RADIUS OF GYRATION (Rx):	2.196 IN	SECTION MODULUS (Sx):	0.399 IN <sup>3</sup>
GROSS MOMENT OF INERTIA (Iy):	0.047 IN <sup>4</sup>	ALLOWABLE BENDING MOMENT (Ma):	7021 IN- LBS
GROSS RADIUS OF GYRATION (Ry):	0.394 IN	ALLOWABLE SHEAR FORCE (Vag):	630 LB
		ALLOWABLE SHEAR FORCE (VANET):	630 LB

#### TORSIONAL PROPERTIES

ST VENANT TORSION CONSTANT (J x 1000):	0.121 IN <sup>4</sup>
WARPING CONSTANT (Cw):	0.332 IN <sup>6</sup>
DISTANCE FROM SHEAR CENTER TO NEUTRAL AXIS (Xo):	-0.647 IN
RADII OF GYRATION (Ro):	2.323 IN
TORSIONAL FLEXURAL CONSTANT (B):	0.922
UNBRACED LENGTH (LU):	28.6 IN

## SECTION PROPERTIES TABLE NOTES:

- CALCULATED PROPERTIES ARE BASED ON AISI S100-12, NORTH AMERICAN SPECIFICATION FOR DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS AND AISI S220-15, NORTH AMERICAN STANDARD FOR COLD-FORMED STEEL FRAMINGâ€"NONSTRUCTURAL MEMBERS.
- EFFECTIVE PROPERTIES INCORPORATE THE STRENGTH INCREASE FROM THE COLD WORK OF FORMING AS APPLICABLE PER AISI A7.2.
- TABULATED GROSS PROPERTIES, INCLUDING TORSIONAL PROPERTIES, ARE BASED ON FULL-UNREDUCED CROSS SECTION OF THE STUDS, AWAY FROM PUNCHOUTS
- TABULATED GROSS PROPERTIES, INCLUDING TORSIONAL PROPERTIES, ARE BASED ON FULL-UNREDUCED CROSS SECTION OF THE TRACKS.
- FOR DEFLECTION CALCULATIONS, USE THE EFFECTIVE MOMENT OF INERTIA.
- ALLOWABLE MOMENT INCLUDES COLD WORK OF FORMING.
- ALLOWABLE MOMENT IS TAKEN AS THE LOWEST VALUE BASED ON LOCAL OR DISTORTIONAL BUCKLING. DISTORTIONAL BUCKLING STRENGTH IS BASED ON A K-PHI = 0.
- WEB DEPTH FOR TRACK SECTIONS IS EQUAL TO THE NOMINAL HEIGHT PLUS TWO TIMES THE DESIGN THICKNESS PLUS THE BEND RADIUS. HEMS ON NONSTRUCTURAL TRACK SECTIONS ARE IGNORED

## LEED:

- COMPLIES WITH ASTM C955
- $\bullet \ \ \mathsf{LEED} \ \mathsf{CREDITS} \ \mathsf{MR} \ \mathsf{2:CONSTRUCTION} \ \mathsf{WASTE} \ \mathsf{MATERIAL}\text{-}\mathsf{RAM} \ \mathsf{STEEL} \ \mathsf{FRAMING} \ \mathsf{IS} \ \mathsf{100\%} \ \mathsf{RECYCLEABLE}$
- LEED CREDITS MR 4: RAM STEEL FRAMING IS FORMED WITH A MINIMUM 25.5% POST CONSUMER AND 14.4% PRE-CONSUMER CONTENT
- LEED CREDITS MR 5: REGIONAL MATERIALS MAY APPLY



# SUBMITTAL SHEET Tech Support: 305.634.0012

PRODUCT CATEGORY: ProSTUD
PRODUCT NUMBER 600PDS125-33

COMPOSITE LIMITING HEIGHT	S								
SPACING INCHES	5 PSF			7.5 PSF			10 PSF		
	L/120	L/240	L/360	L/120	L/240	L/360	L/120	L/240	L/360
12	36' 8"	30' 1"	26' 6"	32' 0"	26' 3"	23' 2"	29' 1"	23' 10"	21' 0"
16	33' 3"	27' 4"	24' 1"	29' 1"	23' 10"	21' 0"	26' 5"	21' 8"	19' 1"
24	29' 1"	23' 10"	21' 0"	25' 5"	20' 10"	18' 4"	23' 1"	18' 11"	

#### COMPOSITE TABLE NOTES:

- ALLOWABLE COMPOSITE LIMITING HEIGHTS WERE DETERMINED IN ACCORDANCE WITH ICC-ES AC86-2015.
- ADDITIONAL COMPOSITE WALL TESTING AND ANALYSIS REQUIREMENTS OF THE SFIA CODE COMPLIANCE CERTIFICATION PROGRAM WERE OBSERVED.
- IN ACCORDANCE WITH CURRENT BUILDING CODES AND AISI DESIGN STANDARDS, THE 1/3 STRESS INCREASE FOR STRENGTH WAS NOT USED.
- THE COMPOSITE LIMITING HEIGHTS PROVIDED IN THE TABLES ARE BASED ON A SINGLE LAYER OF 5/8" TYPE X GYPSUM BOARD FROM THE FOLLOWING MANUFACTURERS: AMERICAN, CERTAINTEED, GEORGIA PACIFIC, CONTINENTAL, NATIONAL, PABCO, AND USG.
- THE GYPSUM BOARD MUST BE APPLIED FULL HEIGHT IN THE VERTICAL ORIENTATION TO EACH STUD FLANGE AND INSTALLED IN
  ACCORDANCE WITH ASTM C754
  USING MINIMUM NO. 6 TYPE S DRYWALL SCREWS SPACED AS LISTED BELOW:
- SCREWS SPACED A MINIMUM OF 16 IN. O.C. TO FRAMING MEMBERS SPACED AT 16 IN. OR 12 IN. O.C.
- SCREWS SPACED A MINIMUM OF 12 IN. O.C. TO FRAMING MEMBERS SPACED AT 24 IN. O.C.
- NO FASTENERS ARE REQUIRED FOR ATTACHING THE STUD TO THE TRACK EXCEPT AS DETAILED IN ASTM C754.
- STUD END BEARING MUST BE A MINIMUM OF 1 INCH.
- F ADJACENT TO THE HEIGHT VALUE INDICATES THAT FLEXURAL STRESS CONTROLS THE ALLOWABLE WALL HEIGHT.
- S ADJACENT TO THE HEIGHT VALUE INDICATES THAT SHEAR/END REACTION CONTROLS THE ALLOWABLE WALL HEIGHT.

NON-COMPOSITE LIMITIN	IG HEIGHTS									
SPACING INCHES	5 PSF	5 PSF			7.5 PSF			10 PSF		
	L/120	L/240	L/360	L/120	L/240	L/360	L/120	L/240	L/360	
12	30' 7"	26' 7"	23' 2"	25' 0"	23' 2"	20'3"	21'8"	21' 1"	18' 5"	
16	26' 6"	24' 1"	21' 1"	21' 8"	21' 1"	18' 5"	18' 9"	18' 9"	16' 9"	
24	21' 8"	21' 1"	18' 5"	17' 8"	17' 8"	16' 1"	15' 4"	15' 4"	14' 7"	

## NON-COMPOSITE TABLE NOTES

- HEIGHTS ARE BASED ON AISI S100-12, NORTH AMERICAN SPECIFICATION AND AISI S220-15, NORTH AMERICAN STANDARD FOR COLD-FORMED STEEL FRAMING NONSTRUCTURAL MEMBERS, USING STEEL PROPERTIES ALONE.
- ABOVE LISTED NON-COMPOSITE LIMITING HEIGHTS ARE APPLICABLE WHEN THE UNBRACED LENGTH IS LESS THAN OR EQUAL TO LU.
- HEIGHTS ARE LIMITED BY MOMENT, DEFLECTION, SHEAR, AND WEB CRIPPLING (ASSUMING 1' END REACTION BEARING).
- WEB STIFFENERS ARE REQUIRED AT BEARING POINTS.