

Wedge-All® Design Information — Concrete



Carbon-Steel Wedge-All Allowable Tension Loads in Normal-Weight Concrete


Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Tension Load								Install. Torque ft.-lb. (N·m)	
				$f'_c \geq 2,000 \text{ psi}$ (13.8 MPa) Concrete			$f'_c \geq 3,000 \text{ psi}$ (20.7 MPa) Concrete			$f'_c \geq 4,000 \text{ psi}$ (27.6 MPa) Concrete			
				Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allowable lb. (kN)	Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allowable lb. (kN)	Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allowable lb. (kN)	
$\frac{1}{4}$ (6.4)	$1\frac{1}{8}$ (29)	$2\frac{1}{2}$ (64)	$1\frac{5}{8}$ (41)	680 (3.0)	167 (0.7)	170 (0.8)	205 (0.9)	960 (4.3)	233 (1.0)	240 (1.1)	240 (1.1)	8 (10.8)	
	$2\frac{1}{4}$ (57)	$2\frac{1}{2}$ (64)	$3\frac{1}{8}$ (79)	1,920 (8.5)	286 (1.3)	480 (2.1)	530 (2.4)	2,320 (10.3)	105 (0.5)	580 (2.6)	580 (2.6)		
$\frac{3}{8}$ (9.5)	$1\frac{3}{4}$ (44)	$3\frac{3}{4}$ (95)	$2\frac{3}{8}$ (60)	1,560 (6.9)	261 (1.2)	390 (1.7)	555 (2.5)	2,880 (12.8)	588 (2.6)	720 (3.2)	720 (3.2)	30 (40.7)	
	$2\frac{5}{8}$ (67)	$3\frac{3}{4}$ (95)	$3\frac{5}{8}$ (92)	3,360 (14.9)	464 (2.1)	840 (3.7)	1,100 (4.9)	5,440 (24.2)	553 (2.5)	1,360 (6.0)	1,360 (6.0)		
	$3\frac{3}{8}$ (86)	$3\frac{3}{4}$ (95)	$4\frac{3}{4}$ (121)	3,680 (16.4)	585 (2.6)	920 (4.1)	1,140 (5.1)	5,440 (24.2)	318 (1.4)	1,360 (6.0)	1,360 (6.0)		
$\frac{1}{2}$ (12.7)	$2\frac{1}{4}$ (57)	5 (127)	$3\frac{1}{8}$ (79)	3,280 (14.6)	871 (3.9)	820 (3.6)	1,070 (4.8)	5,280 (23.5)	849 (3.8)	1,320 (5.9)	1,320 (5.9)	60 (81.3)	
	$3\frac{3}{8}$ (86)	5 (127)	$4\frac{3}{4}$ (121)	6,040 (26.9)	654 (2.9)	1,510 (6.7)	1,985 (8.8)	9,840 (43.8)	1,303 (5.8)	2,460 (10.9)	2,460 (10.9)		
	$4\frac{1}{2}$ (114)	5 (127)	$6\frac{1}{4}$ (159)	6,960 (31.0)	839 (3.7)	1,740 (7.7)	2,350 (10.5)	11,840 (52.7)	2,462 (11.0)	2,960 (13.2)	2,960 (13.2)		
$\frac{5}{8}$ (15.9)	$2\frac{3}{4}$ (70)	$6\frac{1}{4}$ (159)	$3\frac{7}{8}$ (98)	4,520 (20.1)	120 (0.5)	1,130 (5.0)	1,640 (7.3)	8,600 (38.3)	729 (3.2)	2,150 (9.6)	2,150 (9.6)	90 (122.0)	
	$4\frac{1}{2}$ (114)	$6\frac{1}{4}$ (159)	$6\frac{1}{4}$ (159)	8,200 (36.5)	612 (2.7)	2,050 (9.1)	2,990 (13.3)	15,720 (69.9)	1,224 (5.4)	3,930 (17.5)	3,930 (17.5)		
	$5\frac{1}{2}$ (140)	$6\frac{1}{4}$ (159)	$7\frac{3}{4}$ (197)	8,200 (36.5)	639 (2.8)	2,050 (9.1)	2,990 (13.3)	15,720 (69.9)	1,116 (5.0)	3,930 (17.5)	3,930 (17.5)		
$\frac{3}{4}$ (19.1)	$3\frac{3}{8}$ (86)	$7\frac{1}{2}$ (191)	$4\frac{3}{4}$ (121)	6,760 (30.1)	1,452 (6.5)	1,690 (7.5)	2,090 (9.3)	9,960 (44.3)	1,324 (5.9)	2,490 (11.1)	2,490 (11.1)	150 (203.4)	
	5 (127)	$7\frac{1}{2}$ (191)	7 (178)	10,040 (44.7)	544 (2.4)	2,510 (11.2)	3,225 (14.3)	15,760 (70.1)	1,550 (6.9)	3,940 (17.5)	3,940 (17.5)		
	$6\frac{3}{4}$ (171)	$7\frac{1}{2}$ (191)	$9\frac{1}{2}$ (241)	10,040 (44.7)	1,588 (7.1)	2,510 (11.2)	3,380 (15.0)	17,000 (75.6)	1,668 (7.4)	4,250 (18.9)	4,250 (18.9)		
$\frac{7}{8}$ (22.2)	$3\frac{7}{8}$ (98)	$8\frac{3}{4}$ (222)	$5\frac{3}{8}$ (137)	7,480 (33.3)	821 (3.7)	1,870 (8.3)	2,275 (10.1)	10,720 (47.7)	1,253 (5.6)	2,680 (11.9)	2,680 (11.9)	200 (271.2)	
	$7\frac{7}{8}$ (200)	$8\frac{3}{4}$ (222)	11 (279)	17,040 (75.8)	1,566 (7.0)	4,260 (18.9)	4,670 (20.8)	20,320 (90.4)	2,401 (10.7)	5,080 (22.6)	5,080 (22.6)		
1 (25.4)	$4\frac{1}{2}$ (114)	10 (254)	$6\frac{1}{4}$ (159)	11,550 (51.4)	1,830 (8.1)	2,888 (12.8)	2,891 (12.9)	11,760 (52.3)	1,407 (6.3)	2,940 (13.1)	2,940 (13.1)	225 (305.1)	
	9 (229)	10 (254)	$12\frac{1}{2}$ (321)	15,570 (69.3)	2,337 (10.4)	3,893 (17.3)	4,766 (21.2)	22,560 (100.4)	1,209 (5.4)	5,640 (25.1)	5,640 (25.1)		
$1\frac{1}{4}$ (31.8)	$5\frac{5}{8}$ (143)	$12\frac{1}{2}$ (318)	$7\frac{7}{8}$ (200)	11,370 (50.6)	1,010 (4.5)	2,843 (12.6)	3,743 (16.6)	18,570 (82.6)	469 (2.1)	4,643 (20.7)	4,643 (20.7)	400 (542.3)	
	$9\frac{1}{2}$ (241)	$12\frac{1}{2}$ (318)	$13\frac{1}{4}$ (337)	15,120 (67.3)	2,438 (10.8)	3,780 (16.8)	6,476 (28.8)	36,690 (163.2)	1,270 (5.6)	9,173 (40.8)	9,173 (40.8)		

- The allowable loads listed are based on a safety factor of 4.0.
- Refer to allowable load-adjustment factors for edge distance and spacing on pp. 131 and 133.
- Drill bit diameter used in base material corresponds to nominal anchor diameter.
- Allowable loads may be linearly interpolated between concrete strengths listed.
- The minimum concrete thickness is $1\frac{1}{2}$ times the embedment depth.

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete

Carbon-Steel Wedge-All Allowable Shear Loads in Normal-Weight Concrete



Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Shear Load					Install. Torque ft.-lb. (N-m)
				$f'_c \geq 2,000 \text{ psi}$ (13.8 MPa) Concrete			$f'_c \geq 3,000 \text{ psi}$ (20.7 MPa) Concrete	$f'_c \geq 4,000 \text{ psi}$ (27.6 MPa) Concrete	
				Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allowable lb. (kN)	Allowable lb. (kN)	Allowable lb. (kN)	
$\frac{1}{4}$ (6.4)	$1\frac{1}{8}$ (29)	$2\frac{1}{2}$ (64)	$1\frac{5}{8}$ (41)	920 (4.1)	47 (0.2)	230 (1.0)	230 (1.0)	230 (1.0)	8 (10.8)
	$2\frac{1}{4}$ (57)	$2\frac{1}{2}$ (64)	$3\frac{1}{8}$ (79)	—	—	230 (1.0)	230 (1.0)	230 (1.0)	
$\frac{3}{8}$ (9.5)	$1\frac{1}{4}$ (44)	$3\frac{3}{4}$ (95)	$2\frac{5}{8}$ (60)	2,280 (10.1)	96 (0.4)	570 (2.5)	570 (2.5)	570 (2.5)	30 (40.7)
	$2\frac{5}{8}$ (67)	$3\frac{3}{4}$ (95)	$3\frac{5}{8}$ (92)	4,220 (18.8)	384 (1.7)	1,055 (4.7)	1,055 (4.7)	1,055 (4.7)	
	$3\frac{3}{8}$ (86)	$3\frac{3}{4}$ (95)	$4\frac{1}{4}$ (121)	—	—	1,055 (4.7)	1,055 (4.7)	1,055 (4.7)	
$\frac{1}{2}$ (12.7)	$2\frac{1}{4}$ (57)	5 (127)	$3\frac{1}{8}$ (79)	6,560 (29.2)	850 (3.8)	1,345 (6.0)	1,485 (6.6)	1,625 (7.2)	60 (81.3)
	$3\frac{3}{8}$ (86)	5 (127)	$4\frac{1}{4}$ (121)	8,160 (36.3)	880 (3.9)	1,675 (7.5)	1,850 (8.2)	2,020 (9.0)	
	$4\frac{1}{2}$ (114)	5 (127)	$6\frac{1}{4}$ (159)	—	—	1,675 (7.5)	1,850 (8.2)	2,020 (9.0)	
$\frac{5}{8}$ (15.9)	$2\frac{3}{4}$ (70)	$6\frac{1}{4}$ (159)	$3\frac{7}{8}$ (98)	8,720 (38.8)	1,699 (7.6)	1,620 (7.2)	1,900 (8.5)	2,180 (9.7)	90 (122.0)
	$4\frac{1}{2}$ (114)	$6\frac{1}{4}$ (159)	$6\frac{1}{4}$ (159)	12,570 (55.9)	396 (1.8)	2,330 (10.4)	2,740 (12.2)	3,145 (14.0)	
	$5\frac{1}{2}$ (140)	$6\frac{1}{4}$ (159)	$7\frac{3}{4}$ (197)	—	—	2,330 (10.4)	2,740 (12.2)	3,145 (14.0)	
$\frac{3}{4}$ (19.1)	$3\frac{3}{8}$ (86)	$7\frac{1}{2}$ (191)	$4\frac{1}{4}$ (121)	11,360 (50.5)	792 (3.5)	2,840 (12.6)	2,840 (12.6)	2,840 (12.6)	150 (203.4)
	5 (127)	$7\frac{1}{2}$ (191)	7 (178)	18,430 (82.0)	1,921 (8.5)	4,610 (20.5)	4,610 (20.5)	4,610 (20.5)	
	$6\frac{3}{4}$ (171)	$7\frac{1}{2}$ (191)	$9\frac{1}{2}$ (241)	—	—	4,610 (20.5)	4,610 (20.5)	4,610 (20.5)	
$\frac{7}{8}$ (22.2)	$3\frac{7}{8}$ (98)	$8\frac{3}{4}$ (222)	$5\frac{3}{8}$ (137)	13,760 (61.2)	2,059 (9.2)	3,440 (15.3)	3,440 (15.3)	3,440 (15.3)	200 (271.2)
	$7\frac{7}{8}$ (200)	$8\frac{3}{4}$ (222)	11 (279)	22,300 (99.2)	477 (2.1)	5,575 (24.8)	5,575 (24.8)	5,575 (24.8)	
1 (25.4)	$4\frac{1}{2}$ (114)	10 (254)	$6\frac{1}{4}$ (159)	22,519 (100.2)	1,156 (5.1)	5,730 (25.5)	5,730 (25.5)	5,730 (25.5)	300 (406.7)
	9 (229)	10 (254)	$12\frac{5}{8}$ (321)	25,380 (112.9)	729 (3.2)	6,345 (28.2)	6,345 (28.2)	6,345 (28.2)	
$1\frac{1}{4}$ (31.8)	$5\frac{5}{8}$ (143)	$12\frac{1}{2}$ (318)	$7\frac{7}{8}$ (200)	29,320 (130.4)	2,099 (9.3)	7,330 (32.6)	7,330 (32.6)	7,330 (32.6)	400 (542.3)
	$9\frac{1}{2}$ (241)	$12\frac{1}{2}$ (318)	$13\frac{1}{4}$ (337)	—	—	7,330 (32.6)	7,330 (32.6)	7,330 (32.6)	

1. The allowable loads listed are based on a safety factor of 4.0.

2. Refer to allowable load-adjustment factors for spacing and edge distance on pp. 132, 134 and 135.

3. Drill bit diameter used in base material corresponds to nominal anchor diameter.

4. Allowable loads may be linearly interpolated between concrete strengths listed.

5. The minimum concrete thickness is $1\frac{1}{2}$ times the embedment depth.

Wedge-All® Design Information — Concrete



Stainless-Steel Wedge-All Allowable Tension Loads in Normal-Weight Concrete

Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Allowable Tension Load lb. (kN)			Install. Torque ft.-lb. (N·m)
				$f'_c \geq 2,000 \text{ psi}$ (13.8 MPa) Concrete	$f'_c \geq 3,000 \text{ psi}$ (20.7 MPa) Concrete	$f'_c \geq 4,000 \text{ psi}$ (27.6 MPa) Concrete	
$\frac{1}{4}$ (6.4)	$1\frac{1}{8}$ (29)	$2\frac{1}{2}$ (64)	$1\frac{1}{8}$ (41)	155 (0.7)	185 (0.8)	215 (1.0)	8 (10.8)
	$2\frac{1}{4}$ (57)	$2\frac{1}{2}$ (64)	$3\frac{1}{8}$ (79)	430 (1.9)	475 (2.1)	520 (2.3)	
$\frac{3}{8}$ (9.5)	$1\frac{3}{4}$ (44)	$3\frac{3}{4}$ (95)	$2\frac{1}{8}$ (60)	350 (1.6)	500 (2.2)	650 (2.9)	30 (40.7)
	$2\frac{5}{8}$ (67)	$3\frac{3}{4}$ (95)	$3\frac{1}{8}$ (92)	755 (3.4)	990 (4.4)	1,225 (5.4)	
	$3\frac{3}{8}$ (86)	$3\frac{3}{4}$ (95)	$4\frac{1}{4}$ (121)	830 (3.7)	1,025 (4.6)	1,225 (5.4)	
$\frac{1}{2}$ (12.7)	$2\frac{1}{4}$ (57)	5 (127)	$3\frac{1}{8}$ (79)	740 (3.3)	965 (4.3)	1,190 (5.3)	60 (81.3)
	$3\frac{3}{8}$ (86)	5 (127)	$4\frac{1}{4}$ (121)	1,360 (6.0)	1,785 (7.9)	2,215 (9.9)	
	$4\frac{1}{2}$ (114)	5 (127)	$6\frac{1}{4}$ (159)	1,565 (7.0)	2,115 (9.4)	2,665 (11.9)	
$\frac{5}{8}$ (15.9)	$2\frac{3}{4}$ (70)	$6\frac{1}{4}$ (159)	$3\frac{7}{8}$ (98)	1,015 (4.5)	1,475 (6.6)	1,935 (8.6)	90 (122.0)
	$4\frac{1}{2}$ (114)	$6\frac{1}{4}$ (159)	$6\frac{1}{4}$ (159)	1,845 (8.2)	2,690 (12.0)	3,535 (15.7)	
	$5\frac{1}{2}$ (140)	$6\frac{1}{4}$ (159)	$7\frac{3}{4}$ (197)	1,845 (8.2)	2,690 (12.0)	3,535 (15.7)	
$\frac{3}{4}$ (19.1)	$3\frac{3}{8}$ (86)	$7\frac{1}{2}$ (191)	$4\frac{1}{4}$ (121)	1,520 (6.8)	1,880 (8.4)	2,240 (10.0)	150 (203.4)
	5 (127)	$7\frac{1}{2}$ (191)	7 (178)	2,260 (10.1)	2,905 (12.9)	3,545 (15.8)	
	$6\frac{3}{4}$ (171)	$7\frac{1}{2}$ (191)	$9\frac{1}{2}$ (241)	2,260 (10.1)	3,040 (13.5)	3,825 (17.0)	
$\frac{7}{8}$ (22.2)	$3\frac{7}{8}$ (98)	$8\frac{3}{4}$ (222)	$5\frac{1}{8}$ (137)	1,685 (7.5)	2,050 (9.1)	2,410 (10.7)	200 (271.2)
	$7\frac{7}{8}$ (200)	$8\frac{3}{4}$ (222)	11 (279)	3,835 (17.1)	4,205 (18.7)	4,570 (20.3)	
1 (25.4)	$4\frac{1}{2}$ (114)	10 (254)	$6\frac{1}{4}$ (159)	2,599 (11.6)	2,621 (11.7)	2,648 (11.8)	225 (305.1)
	9 (229)	10 (254)	$12\frac{1}{8}$ (321)	3,503 (15.6)	4,290 (19.1)	5,078 (22.6)	
$1\frac{1}{4}$ (31.8)	$5\frac{5}{8}$ (143)	$12\frac{1}{2}$ (318)	$7\frac{7}{8}$ (200)	2,558 (11.4)	3,368 (15.0)	4,178 (18.6)	400 (542.3)
	$9\frac{1}{2}$ (241)	$12\frac{1}{2}$ (318)	$13\frac{1}{4}$ (337)	3,401 (15.1)	5,828 (25.9)	8,254 (36.7)	

- The allowable loads listed are based on a safety factor of 4.0.
- Refer to allowable load-adjustment factors for edge distance and spacing on pp. 131 and 133.
- Drill bit diameter used in base material corresponds to nominal anchor diameter.
- Allowable loads may be linearly interpolated between concrete strengths listed.
- The minimum concrete thickness is $1\frac{1}{2}$ times the embedment depth.

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete

Stainless-Steel Wedge-All Allowable Shear Loads in Normal-Weight Concrete



*

Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Allowable Shear Load lb. (kN)			Install. Torque ft.-lb. (N-m)
				$f'_c \geq 2,000$ psi (13.8 MPa) Concrete	$f'_c \geq 3,000$ psi (20.7 MPa) Concrete	$f'_c \geq 4,000$ psi (27.6 MPa) Concrete	
$\frac{1}{4}$ (6.4)	$1\frac{1}{8}$ (29)	$2\frac{1}{2}$ (64)	$1\frac{5}{8}$ (41)	265 (1.2)	265 (1.2)	265 (1.2)	8 (10.8)
	$2\frac{1}{4}$ (57)	$2\frac{1}{2}$ (64)	$3\frac{1}{8}$ (79)	265 (1.2)	265 (1.2)	265 (1.2)	
$\frac{3}{8}$ (9.5)	$1\frac{9}{16}$ (44)	$3\frac{3}{4}$ (95)	$2\frac{7}{8}$ (60)	655 (2.9)	655 (2.9)	655 (2.9)	30 (40.7)
	$2\frac{5}{8}$ (67)	$3\frac{3}{4}$ (95)	$3\frac{5}{8}$ (92)	1,215 (5.4)	1,215 (5.4)	1,215 (5.4)	
	$3\frac{3}{8}$ (86)	$3\frac{3}{4}$ (95)	$4\frac{1}{4}$ (121)	1,215 (5.4)	1,215 (5.4)	1,215 (5.4)	
$\frac{1}{2}$ (12.7)	$2\frac{1}{4}$ (57)	5 (127)	$3\frac{1}{8}$ (79)	1,545 (6.9)	1,710 (7.6)	1,870 (8.3)	60 (81.3)
	$3\frac{3}{8}$ (86)	5 (127)	$4\frac{3}{4}$ (121)	1,925 (8.6)	2,130 (9.5)	2,325 (10.3)	
	$4\frac{1}{2}$ (114)	5 (127)	$6\frac{1}{4}$ (159)	1,925 (8.6)	2,130 (9.5)	2,325 (10.3)	
$\frac{5}{8}$ (15.9)	$2\frac{3}{4}$ (70)	$6\frac{1}{4}$ (159)	$3\frac{7}{8}$ (98)	1,865 (8.3)	2,185 (9.7)	2,505 (11.1)	90 (122.0)
	$4\frac{1}{2}$ (114)	$6\frac{1}{4}$ (159)	$6\frac{1}{4}$ (159)	2,680 (11.9)	3,150 (14.0)	3,615 (16.1)	
	$5\frac{1}{2}$ (140)	$6\frac{1}{4}$ (159)	$7\frac{3}{4}$ (197)	2,680 (11.9)	3,150 (14.0)	3,615 (16.1)	
$\frac{3}{4}$ (19.1)	$3\frac{3}{8}$ (86)	$7\frac{1}{2}$ (191)	$4\frac{1}{4}$ (121)	3,265 (14.5)	3,265 (14.5)	3,265 (14.5)	150 (203.4)
	5 (127)	$7\frac{1}{2}$ (191)	7 (178)	5,300 (23.6)	5,300 (23.6)	5,300 (23.6)	
	$6\frac{3}{4}$ (171)	$7\frac{1}{2}$ (191)	$9\frac{1}{2}$ (241)	5,300 (23.6)	5,300 (23.6)	5,300 (23.6)	
$\frac{7}{8}$ (22.2)	$3\frac{7}{8}$ (98)	$8\frac{3}{4}$ (222)	$5\frac{3}{8}$ (137)	3,955 (17.6)	3,955 (17.6)	3,955 (17.6)	200 (271.2)
	$7\frac{7}{8}$ (200)	$8\frac{3}{4}$ (222)	11 (279)	6,410 (28.5)	6,410 (28.5)	6,410 (28.5)	
1 (25.4)	$4\frac{1}{2}$ (114)	10 (254)	$6\frac{1}{4}$ (159)	6,590 (29.3)	6,590 (29.3)	6,590 (29.3)	300 (406.7)
	9 (229)	10 (254)	$12\frac{5}{8}$ (321)	7,295 (32.4)	7,295 (32.4)	7,295 (32.4)	
$1\frac{1}{4}$ (31.8)	$5\frac{5}{8}$ (143)	$12\frac{1}{2}$ (318)	$7\frac{7}{8}$ (200)	8,430 (37.5)	8,430 (37.5)	8,430 (37.5)	400 (542.3)
	$9\frac{1}{2}$ (241)	$12\frac{1}{2}$ (318)	$13\frac{1}{4}$ (337)	8,430 (37.5)	8,430 (37.5)	8,430 (37.5)	


1. The allowable loads listed are based on a safety factor of 4.0.

2. Refer to allowable load-adjustment factors for spacing and edge distance on pp. 131–132 and 134.

3. Drill bit diameter used in base material corresponds to nominal anchor diameter.

4. Allowable loads may be linearly interpolated between concrete strengths listed.

5. The minimum concrete thickness is $1\frac{1}{2}$ times the embedment depth.



Carbon-Steel Wedge-All Allowable Tension Loads in Sand-Lightweight Concrete over Steel Deck



Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Tension Load (Install in Concrete)			Tension Load (Install Through Steel Deck)			Install. Torque ft.-lb. (N-m)	
				$f'_c \geq 3,000 \text{ psi (20.7 MPa)}$ Concrete			$f'_c \geq 3,000 \text{ psi (20.7 MPa)}$ Concrete				
				Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allow. lb. (kN)	Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allow. lb. (kN)		
1/4 (6.4)	1 1/2 (38)	3 3/8 (86)	2 3/4 (70)	—	—	—	1,440 (6.4)	167 (0.7)	360 (1.6)	—	
1/2 (12.7)	2 1/4 (57)	6 3/4 (171)	4 1/8 (105)	3,880 (17.3)	228 (1.0)	970 (4.3)	3,860 (17.2)	564 (2.5)	965 (4.3)	60 (81.3)	
5/8 (15.9)	2 3/4 (70)	8 3/8 (213)	5 (127)	5,920 (26.3)	239 (1.1)	1,480 (6.6)	5,220 (23.2)	370 (1.6)	1,305 (5.8)	90 (122.0)	
3/4 (19.1)	3 3/8 (86)	10 (254)	6 1/8 (156)	7,140 (31.8)	537 (2.4)	1,785 (7.9)	6,600 (29.4)	903 (4.0)	1,650 (7.3)	150 (203.4)	

See footnotes 1–7 below.

Carbon-Steel Wedge-All Allowable Shear Loads in Sand-Lightweight Concrete over Steel Deck




Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical Spacing in. (mm)	Shear Load (Install in Concrete)			Shear Load (Install Through Steel Deck)			Install. Torque ft.-lb. (N-m)	
				$f'_c \geq 3,000 \text{ psi (20.7 MPa)}$ Concrete			$f'_c \geq 3,000 \text{ psi (20.7 MPa)}$ Concrete				
				Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allow. lb. (kN)	Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allow. lb. (kN)		
1/4 (6.4)	1 1/2 (38)	3 3/8 (86)	2 3/4 (70)	—	—	—	1,660 (7.4)	627 (2.8)	415 (1.8)	—	
1/2 (12.7)	2 1/4 (57)	6 3/4 (171)	4 1/8 (105)	5,575 (24.8)	377 (1.7)	1,395 (6.2)	7,260 (32.3)	607 (2.7)	1,815 (8.1)	60 (81.3)	
5/8 (15.9)	2 3/4 (70)	8 3/8 (213)	5 (127)	8,900 (39.6)	742 (3.3)	2,225 (9.9)	8,560 (38.1)	114 (0.5)	2,140 (9.5)	90 (122.0)	
3/4 (19.1)	3 3/8 (86)	10 (254)	6 1/8 (156)	10,400 (46.3)	495 (2.2)	2,600 (11.6)	11,040 (49.1)	321 (1.4)	2,760 (12.3)	150 (203.4)	

- The allowable loads listed are based on a safety factor of 4.0.
- Refer to allowable load-adjustment factors for edge distance on p. 135.
- 100% of the allowable load is permitted at critical spacing. Loads at reduced spacing have not been determined.
- Drill bit diameter used in base material corresponds to nominal anchor diameter.


- The minimum concrete thickness is 1 1/2 times the embedment depth.
- Steel deck must be minimum 20 gauge.
- Anchors installed in the bottom flute of the steel deck must have a minimum allowable edge distance of 1 1/2" from the inclined edge of the bottom flute.

Carbon-Steel Wedge-All Allowable Tension and Shear Loads in Grout-Filled CMU




Size in. (mm)	Embed. Depth in. (mm)	Critical Edge Dist. in. (mm)	Critical End Dist. in. (mm)	Critical Spacing in. (mm)	8" Grout-Filled CMU Allowable Load Based on CMU Strength						Install. Torque ft.-lb. (N-m)	
					Tension Load			Shear Load				
					Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allow. lb. (kN)	Ultimate lb. (kN)	Std. Dev. lb. (kN)	Allow. lb. (kN)		
Anchor Installed on the Face of the CMU Wall at Least 1 1/4 inch Away from Head Joint (See Figure)												
5/8 (9.5)	2 5/8 (267)	10 1/2 (267)	10 1/2 (267)	10 1/2 (267)	1,700 (7.6)	129 (0.6)	340 (1.5)	3,360 (14.9)	223 (1.0)	670 (3.0)	30 (40.7)	
1/2 (12.7)	3 1/2 (356)	14 (356)	14 (356)	14 (356)	2,120 (9.4)	129 (0.6)	425 (1.9)	5,360 (23.8)	617 (2.7)	1,070 (4.8)	35 (47.4)	
5/8 (15.9)	4 3/8 (445)	17 1/2 (445)	17 1/2 (445)	17 1/2 (445)	3,120 (13.9)	342 (1.5)	625 (2.8)	8,180 (36.4)	513 (2.3)	1,635 (7.3)	55 (74.5)	
3/4 (19.1)	5 1/4 (133)	21 (533)	21 (533)	21 (533)	4,320 (19.2)	248 (1.1)	865 (3.8)	10,160 (45.2)	801 (3.6)	2,030 (9.0)	120 (162.6)	

- The tabulated allowable loads are based on a safety factor of 5.0 for installations under the IBC and IRC.
- Listed loads may be applied to installations on the face of the CMU wall at least 1 1/4" away from head joints.
- Values for 8"-wide concrete masonry units (CMU) with a minimum specified compressive strength of masonry, f'_m , at 28 days is 1,500 psi.
- Embedment depth is measured from the outside face of the concrete masonry unit.
- Drill bit diameter used in base material corresponds to nominal anchor diameter.
- Tension and shear loads for the Wedge-All anchor may be combined using the parabolic interaction equation ($n = \%$).
- Refer to allowable load-adjustment factors for edge distance on p. 135.



Lightweight Concrete
on Steel Deck



Shaded area = Placement
for Full and Reduced
Allowable Load Capacity
in Grout-Filled CMU

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete


Allowable Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All Anchors in Normal-Weight Concrete: Edge Distance, Tension and Shear Loads

How to use these charts:

1. The following tables are for reduced edge distance.
2. Locate the anchor size to be used for either a tension and/or shear load application.
3. Locate the edge distance (c_{act}) at which the anchor is to be installed.
4. The load adjustment factor (f_c) is the intersection of the row and column.
5. Multiply the allowable load by the applicable load adjustment factor.
6. Reduction factors for multiple edges are multiplied together.

Edge Distance Tension (f_c)


Edge Dist. (in.)	Size	1/4	3/8	1/2	5/8	3/4	7/8	1	1 1/4
	c_{cr}	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	12 1/2
	c_{min}	1	1 1/2	2	2 1/2	3	3 1/2	4	5
	f_{cmin}	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70
1		0.70							
1 1/2		0.80	0.70						
2		0.90	0.77	0.70					
2 1/2		1.00	0.83	0.75	0.70				
3			0.90	0.80	0.74	0.70			
3 1/2			0.97	0.85	0.78	0.73	0.70		
3 3/4			1.00	0.88	0.80	0.75	0.71		
4				0.90	0.82	0.77	0.73	0.70	
4 1/2				0.95	0.86	0.80	0.76	0.73	
5				1.00	0.90	0.83	0.79	0.75	0.70
5 1/2					0.94	0.87	0.81	0.78	0.72
6					0.98	0.90	0.84	0.80	0.74
6 1/4					1.00	0.92	0.86	0.81	0.75
6 1/2						0.93	0.87	0.83	0.76
7						0.97	0.90	0.85	0.78
7 1/2						1.00	0.93	0.88	0.80
8							0.96	0.90	0.82
8 1/2							0.99	0.93	0.84
8 3/4							1.00	0.94	0.85
10								1.00	0.90
12 1/2									1.00
15									



See footnotes below.

Edge Distance Shear (f_c) (Shear Applied Perpendicular to Edge)

Edge Dist. (in.)	Size	1/4	3/8	1/2	5/8	3/4	7/8	1	1 1/4
	c_{cr}	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	12 1/2
	c_{min}	1	1 1/2	2	2 1/2	3	3 1/2	4	5
	f_{cmin}	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
1		0.30							
1 1/2		0.53	0.30						
2		0.77	0.46	0.30					
2 1/2		1.00	0.61	0.42	0.30				
3			0.77	0.53	0.39	0.30			
3 1/2			0.92	0.65	0.49	0.38	0.30		
3 3/4			1.00	0.71	0.53	0.42	0.33		
4				0.77	0.58	0.46	0.37	0.30	
4 1/2				0.88	0.67	0.53	0.43	0.36	
5				1.00	0.77	0.61	0.50	0.42	0.30
5 1/2					0.86	0.69	0.57	0.48	0.35
6					0.95	0.77	0.63	0.53	0.39
6 1/4					1.00	0.81	0.67	0.56	0.42
6 1/2						0.84	0.70	0.59	0.44
7						0.92	0.77	0.65	0.49
7 1/2						1.00	0.83	0.71	0.53
8							0.90	0.77	0.58
8 1/2							0.97	0.83	0.63
8 3/4							1.00	0.85	0.65
10								1.00	0.77
12 1/2									1.00
15									



1. c_{act} = actual edge distance at which anchor is installed (inches).
2. c_{cr} = critical edge distance for 100% load (inches).
3. c_{min} = minimum edge distance for reduced load (inches).
4. f_c = adjustment factor for allowable load at actual edge distance.
5. f_{ccr} = adjustment factor for allowable load at critical edge distance. f_{ccr} is always = 1.00.
6. f_{cmin} = adjustment factor for allowable load at minimum edge distance.
7. $f_c = f_{cmin} + [(1 - f_{cmin}) (c_{act} - c_{min}) / (c_{cr} - c_{min})]$.

Load-Adjustment Factors for Reduced Spacing:

Critical spacing is listed in the load tables. No adjustment in load is required when the anchors are spaced at critical spacing.

No additional testing has been performed to determine the adjustment factors for spacing dimensions less than those listed in the load tables.

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete


Allowable Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All Anchors in Normal-Weight Concrete: Edge Distance and Shear Load Applied Parallel to Edge

How to use these charts:

1. The following tables are for reduced edge distance.
2. Locate the anchor size to be used for a shear load application.
3. Locate the edge distance ($c_{act||}$) at which the anchor is to be installed.
4. The load adjustment factor ($f_{c||}$) is the intersection of the row and column.
5. Multiply the allowable load by the applicable load adjustment factor.
6. Reduction factors for multiple edges are multiplied together.

Edge Distance Shear ($f_{c||}$) (Shear Applied Parallel to Edge with End Distance $\geq ED_{min}$)

	Size	$\frac{1}{4}$	$\frac{3}{8}$	$\frac{1}{2}$	$\frac{5}{8}$	$\frac{3}{4}$	$\frac{7}{8}$	1	$1\frac{1}{4}$
Edge Dist.	E	2 $\frac{1}{4}$	3 $\frac{3}{8}$	4 $\frac{1}{2}$	5 $\frac{1}{2}$	6 $\frac{3}{4}$	7 $\frac{7}{8}$	9	9 $\frac{1}{2}$
$c_{act }$ (in.)	ED_{min}	9	13 $\frac{1}{2}$	18	22	27	31 $\frac{1}{2}$	36	38
	$c_{cr }$	2 $\frac{1}{2}$	3 $\frac{3}{4}$	5	6 $\frac{1}{4}$	7 $\frac{1}{2}$	8 $\frac{3}{4}$	10	12 $\frac{1}{2}$
	$c_{min }$	1	1 $\frac{1}{2}$	2	2 $\frac{1}{2}$	3	3 $\frac{1}{2}$	4	5
	$f_{cmi }$	1.00	0.93	0.70	0.62	0.62	0.62	0.62	0.62
1		1.00							
1 $\frac{1}{2}$		1.00	0.93						
2		1.00	0.95	0.70					
2 $\frac{1}{2}$		1.00	0.96	0.75	0.62				
3			0.98	0.80	0.67	0.62			
3 $\frac{1}{2}$			0.99	0.85	0.72	0.66	0.62		
4				1.00	0.90	0.77	0.70	0.66	0.62
5					1.00	0.87	0.79	0.73	0.68
6						0.97	0.87	0.80	0.75
7						1.00	0.96	0.87	0.81
8							1.00	0.95	0.87
9								1.00	0.94
10									0.87
11									0.92
12									0.97
13									1.00



1. Table is not applicable to anchors with $ED < ED_{min}$. Factors from this table may not be combined with load-adjustment factors for shear loads applied perpendicular to edge.
2. $c_{act||}$ = actual edge distance (measured perpendicular to direction of shear load) at which anchor is installed (inches).
3. $c_{cr||}$ = critical edge distance (measured perpendicular to direction of shear load) for 100% load (inches).
4. $c_{min||}$ = minimum edge distance (measured perpendicular to direction of shear load) for reduced load (inches).
5. ED = actual end distance (measured parallel to direction of shear load) at which anchor is installed (inches).
6. ED_{min} = minimum edge distance (measured parallel to direction of shear load).
7. $f_{c||}$ = adjustment factor for allowable load at actual edge distance.
8. $f_{ccr||}$ = adjustment factor for allowable load at critical edge distance. $f_{ccr||}$ is always = 1.00.
9. $f_{cmi||}$ = adjustment factor for allowable load at minimum edge distance.
10. $f_{c||} = f_{cmi||} + [(1 - f_{cmi||}) (c_{act||} - c_{min||}) / (c_{cr||} - c_{min||})]$.

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete


Allowable Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All Anchors in Normal-Weight Concrete: Spacing, Tension Loads

How to use these charts:

1. The following tables are for reduced spacing.
2. Locate the anchor size to be used for a tension load application.
3. Locate the anchor embedment (E) used for a tension load application.
4. Locate the spacing (s_{act}) at which the anchor is to be installed.
5. The load adjustment factor (f_s) is the intersection of the row and column.
6. Multiply the allowable load by the applicable load adjustment factor.
7. Reduction factors for multiple spacings are multiplied together.

Spacing Tension (f_s)


s_{act} (in.)	Dia.	$\frac{1}{4}$		$\frac{3}{8}$			$\frac{1}{2}$			$\frac{5}{8}$		
	E	$1\frac{1}{8}$	$2\frac{1}{4}$	$1\frac{3}{4}$	$2\frac{5}{8}$	$3\frac{3}{8}$	$2\frac{1}{4}$	$3\frac{3}{8}$	$4\frac{1}{2}$	$2\frac{3}{4}$	$4\frac{1}{2}$	$5\frac{1}{2}$
	s_{cr}	$1\frac{5}{8}$	$3\frac{1}{8}$	$2\frac{3}{8}$	$3\frac{5}{8}$	$4\frac{3}{4}$	$3\frac{1}{8}$	$4\frac{3}{4}$	$6\frac{1}{4}$	$3\frac{7}{8}$	$6\frac{1}{4}$	$7\frac{3}{4}$
	s_{min}	$\frac{5}{8}$	$1\frac{1}{8}$	$\frac{7}{8}$	$1\frac{1}{8}$	$1\frac{3}{4}$	$1\frac{1}{8}$	$1\frac{3}{4}$	$2\frac{1}{4}$	$1\frac{1}{8}$	$2\frac{1}{4}$	$2\frac{3}{4}$
$\frac{3}{4}$		0.43	0.70	0.43	0.43	0.70	0.43	0.43	0.70	0.43	0.43	0.70
1		0.64		0.48								
$1\frac{1}{4}$		0.79	0.72	0.57			0.47					
$1\frac{1}{2}$		0.93	0.76	0.67	0.46		0.54			0.46		
$1\frac{3}{4}$		1.00	0.79	0.76	0.53	0.70	0.61	0.43		0.52		
2			0.83	0.86	0.59	0.73	0.68	0.48		0.57		
$2\frac{1}{4}$			0.87	0.95	0.65	0.75	0.75	0.53	0.70	0.63	0.43	
$2\frac{1}{2}$				0.91	1.00	0.72	0.78	0.82	0.57	0.72	0.69	0.47
$2\frac{3}{4}$					0.94		0.78	0.80	0.89	0.62	0.74	0.50
3					0.98		0.84	0.83	0.96	0.67	0.76	0.80
$3\frac{1}{2}$					1.00		0.97	0.88	1.00	0.76	0.79	0.91
4						1.00	0.93		0.86	0.83	1.00	0.68
$4\frac{1}{2}$							0.98		0.95	0.87		0.75
5							1.00		1.00	0.91		0.82
6										0.98		0.96
7										1.00		0.96
8												1.00



See footnotes below.

Spacing Tension (f_s)

s_{act} (in.)	Dia.	$\frac{3}{4}$			$\frac{7}{8}$		1		$1\frac{1}{4}$			
	E	$3\frac{3}{8}$	5	$6\frac{3}{4}$	$3\frac{7}{8}$	$7\frac{7}{8}$	$4\frac{1}{2}$	9	$5\frac{5}{8}$	$9\frac{1}{2}$		
	s_{cr}	$4\frac{3}{4}$	7	$9\frac{1}{2}$	$5\frac{3}{8}$	11	$6\frac{1}{4}$	$12\frac{5}{8}$	$7\frac{7}{8}$	$13\frac{1}{4}$		
	s_{min}	$1\frac{3}{4}$	$2\frac{1}{2}$	$3\frac{3}{8}$	2	4	$2\frac{1}{4}$	$4\frac{1}{2}$	$2\frac{7}{8}$	$4\frac{3}{4}$		
2		0.48			0.43							
3		0.67	0.49		0.60		0.54		0.46			
4		0.86	0.62	0.73	0.77	0.70	0.68		0.57			
5		1.00	0.75	0.78	0.94	0.74	0.82	0.72	0.68	0.71		
6		0.87	0.83	1.00		0.79	0.96	0.76	0.79	0.74		
7		1.00	0.88		0.83	1.00	0.79	0.79	0.90	0.78		
8			0.93		0.87		0.83	1.00	0.83	1.00	0.81	
9			0.98		0.91		0.87		0.87		0.85	
10			1.00		0.96		0.90		0.90		0.89	
11					1.00		0.94		0.94		0.92	
12								0.98		0.98		
13								1.00		0.99		
14										1.00		



1. E = Embedment depth (inches).
2. s_{act} = actual spacing distance at which anchors are installed (inches).
3. s_{cr} = critical spacing distance for 100% load (inches).
4. s_{min} = minimum spacing distance for reduced load (inches).
5. f_s = adjustment factor for allowable load at actual spacing distance.
6. f_{scr} = adjustment factor for allowable load at critical spacing distance. f_{scr} is always = 1.00.
7. f_{smin} = adjustment factor for allowable load at minimum spacing distance.
8. $f_s = f_{smin} + [(1 - f_{smin}) (s_{act} - s_{min}) / (s_{cr} - s_{min})]$.

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete


Allowable Load-Adjustment Factors for Carbon-Steel and Stainless-Steel Wedge-All Anchors in Normal-Weight Concrete: Spacing, Shear Loads

How to use these charts:

1. The following tables are for reduced spacing.
2. Locate the anchor size to be used for a shear load application.
3. Locate the anchor embedment (E) used for a shear load application.
4. Locate the spacing (s_{act}) at which the anchor is to be installed.
5. The load adjustment factor (f_s) is the intersection of the row and column.
6. Multiply the allowable load by the applicable load adjustment factor.
7. Reduction factors for multiple spacings are multiplied together.

Spacing Shear (f_s)


s_{act} (in.)	Dia.	$\frac{1}{4}$		$\frac{3}{8}$			$\frac{1}{2}$			$\frac{5}{8}$		
	E	$1\frac{1}{8}$	$2\frac{1}{4}$	$1\frac{3}{4}$	$2\frac{5}{8}$	$3\frac{3}{8}$	$2\frac{1}{4}$	$3\frac{3}{8}$	$4\frac{1}{2}$	$2\frac{3}{4}$	$4\frac{1}{2}$	$5\frac{1}{2}$
	s_{cr}	$1\frac{1}{8}$	$3\frac{1}{8}$	$2\frac{3}{8}$	$3\frac{5}{8}$	$4\frac{3}{4}$	$3\frac{1}{8}$	$4\frac{3}{4}$	$6\frac{1}{4}$	$3\frac{7}{8}$	$6\frac{1}{4}$	$7\frac{3}{4}$
	s_{min}	$5\frac{1}{8}$	$1\frac{1}{8}$	$7\frac{1}{8}$	$1\frac{3}{8}$	$1\frac{3}{4}$	$1\frac{1}{8}$	$1\frac{3}{4}$	$2\frac{1}{4}$	$1\frac{3}{8}$	$2\frac{1}{4}$	$2\frac{3}{4}$
	f_{smin}	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79
$\frac{3}{4}$		0.82										
1		0.87		0.81								
$1\frac{1}{4}$		0.92	0.80	0.84		0.80						
$1\frac{1}{2}$		0.97	0.83	0.88	0.80		0.83			0.80		
$1\frac{3}{4}$		1.00	0.86	0.91	0.83	0.79	0.86	0.79		0.82		
2			0.88	0.95	0.85	0.81	0.88	0.81		0.84		
$2\frac{1}{4}$			0.91	0.98	0.87	0.83	0.91	0.83	0.79	0.86	0.79	
$2\frac{1}{2}$				0.93	1.00	0.90	0.84	0.93	0.84	0.80	0.88	0.80
$2\frac{3}{4}$					0.96	0.92	0.86	0.96	0.86	0.82	0.91	0.82
3					0.99	0.94	0.88	0.99	0.88	0.83	0.93	0.83
$3\frac{1}{2}$					1.00	0.99	0.91	1.00	0.91	0.86	0.97	0.86
4						1.00	0.95		0.95	0.88	1.00	0.88
$4\frac{1}{2}$							0.98		0.98	0.91		0.91
5							1.00		1.00	0.93		0.93
6										0.99		0.99
7										1.00		0.97
8												1.00



See notes below.

Spacing Shear (f_s)

s_{act} (in.)	Dia.	$\frac{3}{4}$		$\frac{7}{8}$			1		$1\frac{1}{4}$			
	E	$3\frac{3}{8}$	5	$6\frac{3}{4}$	$3\frac{7}{8}$	$7\frac{7}{8}$	$4\frac{1}{2}$	9	$5\frac{5}{8}$	$9\frac{1}{2}$		
	s_{cr}	$4\frac{3}{4}$	7	$9\frac{1}{2}$	$5\frac{5}{8}$	11	$6\frac{1}{4}$	$12\frac{5}{8}$	$7\frac{7}{8}$	$13\frac{1}{4}$		
	s_{min}	$1\frac{3}{4}$	$2\frac{1}{2}$	$3\frac{3}{8}$	2	4	$2\frac{1}{4}$	$4\frac{1}{2}$	$2\frac{7}{8}$	$4\frac{3}{4}$		
	f_{smin}	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	
2		0.81			0.79							
3		0.88	0.81		0.85		0.83		0.80			
4		0.95	0.86	0.81	0.91	0.79	0.88		0.84			
5		1.00	0.91	0.85	0.98	0.82	0.93	0.80	0.88	0.80		
6			0.95	0.88	1.00	0.85	0.99	0.83	0.92	0.82		
7				1.00	0.91		0.88	1.00	0.85	0.96	0.85	
8					0.95		0.91		0.88	1.00	0.87	
9					0.98		0.94		0.91		0.90	
10					1.00		0.97		0.93		0.92	
11						1.00		0.96		0.94		
12								0.98		0.97		
13								1.00		0.99		
14										1.00		



1. E = Embedment depth (inches).
2. s_{act} = actual spacing distance at which anchors are installed (inches).
3. s_{cr} = critical spacing distance for 100% load (inches).
4. s_{min} = minimum spacing distance for reduced load (inches).
5. f_s = adjustment factor for allowable load at actual spacing distance.
6. f_{scr} = adjustment factor for allowable load at critical spacing distance. f_{scr} is always = 1.00.
7. f_{smin} = adjustment factor for allowable load at minimum spacing distance.
8. $f_s = f_{smin} + [(1 - f_{smin})(s_{act} - s_{min}) / (s_{cr} - s_{min})]$.

* See p. 12 for an explanation of the load table icons.

Wedge-All® Design Information — Concrete and Masonry

Allowable Load-Adjustment Factors for Carbon-Steel Wedge-All Anchors in Sand-Lightweight Concrete: Edge Distance, Tension and Shear Loads


How to use these charts:

1. The following tables are for reduced edge distance.
2. Locate the anchor size to be used for either a tension and/or shear load application.
3. Locate the edge distance (c_{act}) at which the anchor is to be installed.

4. The load adjustment factor (f_c) is the intersection of the row and column.
5. Multiply the allowable load by the applicable load adjustment factor.
6. Reduction factors for multiple edges are multiplied together.


Edge Distance Tension (f_c)

Edge Dist.	Size	1/4	1/2	5/8	3/4
c_{cr}	3 3/8	6 3/4	8 3/8	10	
c_{act} (in.)	1 1/8	2 3/4	3 3/8	4	
f_{cmin}	0.70	0.70	0.70	0.70	
1 1/8		0.70			
1 1/2		0.72			
2		0.79			
2 1/2		0.87			
2 3/4		0.91	0.70		
3		0.94	0.72		
3 3/8		1.00	0.75	0.70	
3 1/2			0.76	0.71	
4			0.79	0.74	0.70
4 1/2			0.83	0.77	0.73
5			0.87	0.80	0.75
5 1/2			0.91	0.83	0.78
6			0.94	0.86	0.80
6 1/2			0.98	0.89	0.83
6 3/4			1.00	0.90	0.84
7				0.92	0.85
7 1/2				0.95	0.88
8				0.98	0.90
8 3/8				1.00	0.92
8 1/2					0.93
9					0.95
9 1/2					0.98
10					1.00



Edge Distance Shear (f_c)
(Shear Applied Perpendicular to Edge)

Edge Dist.	Size	1/4	1/2	5/8	3/4
c_{cr}	3 3/8	6 3/4	8 3/8	10	
c_{act} (in.)	1 1/8	2 3/4	3 3/8	4	
f_{cmin}	0.30	0.30	0.30	0.30	
1 1/8		0.30			
1 1/2		0.34			
2		0.52			
2 1/2		0.69			
2 3/4		0.78	0.30		
3		0.87	0.34		
3 3/8		1.00	0.41	0.30	
3 1/2			0.43	0.32	
4			0.52	0.39	0.30
4 1/2			0.61	0.46	0.36
5			0.69	0.53	0.42
5 1/2			0.78	0.60	0.48
6			0.87	0.67	0.53
6 1/2			0.96	0.74	0.59
6 3/4			1.00	0.77	0.62
7				0.81	0.65
7 1/2				0.88	0.71
8				0.95	0.77
8 3/8				1.00	0.81
8 1/2					0.83
9					0.88
9 1/2					0.94
10					1.00




See footnotes below.

See footnotes below.

Load Adjustment Factors for Carbon-Steel Wedge-All® Anchors in Face-of-Wall Installation in 8" Grout-Filled CMU: Edge Distance, Tension and Shear Loads

Edge Distance Tension (f_c)

Edge Dist.	Size	3/8	1/2	5/8	3/4
c_{cr}	10 1/2	14	17 1/2	21	
c_{act} (in.)	4	4	4	4	
f_{cmin}	1.00	1.00	0.80	0.80	
4		1.00	1.00	0.80	0.80
6		1.00	1.00	0.83	0.82
8		1.00	1.00	0.86	0.85
10 1/2		1.00	1.00	0.90	0.88
12			1.00	0.92	0.89
14			1.00	0.95	0.92
16				0.98	0.94
17 1/2				1.00	0.96
21					1.00



Edge Distance Shear (f_c)

Edge Dist.	Size	3/8	1/2	5/8	3/4
c_{cr}	10 1/2	14	17 1/2	21	
c_{act} (in.)	4	4	4	4	
f_{cmin}	0.79	0.52	0.32	0.32	
4		0.79	0.52	0.32	0.32
6		0.85	0.62	0.42	0.40
8		0.92	0.71	0.52	0.48
10 1/2		1.00	0.83	0.65	0.58
12			0.90	0.72	0.64
14			1.00	0.82	0.72
16				0.92	0.80
17 1/2				1.00	0.86
21					1.00



Load-Adjustment Factors for Reduced Spacing:

Critical spacing is listed in the load tables. No adjustment in load is required when the anchors are spaced at critical spacing. No additional testing has been performed to determine the adjustment factors for spacing dimensions less than those listed in the load tables.

1. c_{act} = actual edge distance at which anchor is installed (inches).

2. c_{cr} = critical edge distance for 100% load (inches).

3. c_{min} = minimum edge distance for reduced load (inches).

4. f_c = adjustment factor for allowable load at actual edge distance.

5. f_{ccr} = adjustment factor for allowable load at critical edge distance.
 f_{ccr} is always = 1.00.

6. f_{cmin} = adjustment factor for allowable load at minimum edge distance.

7. $f_c = f_{cmin} + [(1 - f_{cmin})(c_{act} - c_{min}) / (c_{cr} - c_{min})]$.

* See p. 12 for an explanation of the load table icons.