

GENERAL CERTIFICATE OF CONFORMANCE

<i>TREMstop Acrylic GG (Gun Grade)</i>	<i>TREMstop Fyre-Sil (Gun Grade)</i>
<i>TREMstop Acrylic SP (Spray)</i>	<i>TREMstop Fyre-Sil SL</i>
<i>TREMstop IA+ (Sealant)</i>	<i>TREMstop SuperStrip</i>
<i>TREMstop FS Blanket</i>	<i>TREMstop Fire Mortar</i>
<i>TREMstop Smoke & Sound (Sealant)</i>	<i>Dymonic FC</i>
<i>TREMstop Smoke & Sound Spray</i>	<i>Vulkem 45SSL</i>
<i>TREMstop MP (Putty Pad)</i>	<i>Dymeric 240FC</i>

These products are tested and/or evaluated to one or more of the following standards at recognized third party test laboratories*:

- ASTM E-119 (UL 263) Fire Tests of Building Construction and Materials
- ASTM E-814 (UL 1479) Fire Tests of Through-Penetration Fire Stops (under positive furnace pressure of minimum .01 inches of water column or +2.5 Pascal)
- ASTM E-2307 Fire Tests for Determining Fire Resistance of Perimeter Fire Barriers Using Intermediate-Scale Multi-Story Test Apparatus
- ASTM E-84 (UL 723) Surface Burning Characteristics of Building Materials
- ASTM E-1966 (UL 2079) Test for Fire Resistance of Building Joint Systems
- CAN/ULC-S101M Standard Methods of Fire Endurance Tests of Building Construction and Materials
- CAN4-S115M Fire Tests of Firestop Systems (under positive furnace pressure of minimum +2.5 Pascal to maximum +50 Pascal)

No asbestos or PCB's are used or contained in these products.

*Recognized third parties test labs include, but are not limited to, Underwriter's Laboratories, Inc., Underwriter's Laboratories of Canada, Intertek Testing Services, Inc., NSF, and FM Global.